

# Town of Wiscasset

## Requests for Bids

### Wastewater Treatment Pump Generators

The Town of Wiscasset Wastewater Department is seeking bids for purchase four backup power generators for placement at sewer pumping stations in the Town of Wiscasset.

The generators must be diesel powered and have built-in fuel tanks. They should have the ability to be hardwired into the pump station controls. The generators will be placed outdoors and subject to all weather conditions.

See below, the addresses, peak demand KWs for each pump station in the last 12 months, and the pump motor specs:

<b>STATION #1, 125 BATH ROAD:</b>	2 Pumps, each 15 HP Peak Demand: 15.24 KW	3-Phase, 60 Cycle, 240 V 52 Amps Max Run Load
<b>STATION #2, 199 BATH ROAD:</b>	2 Pumps, each 15 HP Peak Demand: 9.49 KW	3-Phase, 60 Cycle, 240 V 52 Amps Max Run Load
<b>STATION #3, 341 BATH ROAD:</b>	2 Pumps, each 15 HP Peak Demand: 20.69 KW	3-Phase, 60 Cycle, 240 V 57 Amps Max Run Load
<b>STATION #4, 181 GARDINER RD.:</b>	2 Pumps, each 20 HP Peak Demand: 14.67 KW	3-Phase, 60 Cycle, 240 V 50 Amps Max Run Load

**All Stations use across the line starters, no VFDs.** For sizing purposes, inrush should be calculated. Please include delivery charges on the bid.

Call Wiscasset Sewer Department Supervisor Rob Lalli at 207-882-8222 for an appointment or for further information.

All bids must be SENT IN A SEALED ENVELOPE, MARKED "PUMP STATION GENERATORS", and sent to Manager Dennis Simmons, Town of Wiscasset, 51 Bath Road, Wiscasset, ME 04578. Bids must be received by 4:00 PM February 19<sup>th</sup>, 2021. Bids will be opened and reviewed at the Selectboard meeting March 2<sup>nd</sup>, 2021

The Town of Wiscasset reserves the right to reject any or all bids.